

# MINNESOTA STATE DEPARTMENT OF PUBLIC SAFETY



Alcohol &  
Gambling  
Enforcement

Bureau of  
Criminal  
Apprehension

Capitol Security

Crime Victim  
Services

Driver & Vehicle  
Services

Emergency  
Management /  
Emergency  
Response  
Commission

State Fire  
Marshal /  
Pipeline Safety

State Patrol

Traffic Safety

## State Fire Marshal Division

444 Cedar Street, Suite 145, St. Paul, Minnesota 55101-5145  
Phone: 651/201-7200 FAX: 651/215-0525 TTY: 651/282/6555  
Internet: <http://www.dps.state.mn.us>

### CARBON MONOXIDE ALARMS – MINNESOTA STATUTE 299F.50

The 2006 legislative session passed a new carbon monoxide (CO) law (MN § 299F.50) requiring CO alarms in all single family homes and multifamily apartment units. Effective January 1, 2007 all newly constructed single family homes and multifamily dwelling units for which building permits were issued on or after January 1, 2007 shall be provided with approved carbon monoxide alarms. Effective August 1, 2008, all existing single family homes shall be equipped with approved carbon monoxide alarms. Effective August 1, 2009 all other multifamily or apartment dwelling units shall be provided with approved CO alarms. All carbon monoxide alarms must be certified by a nationally recognized testing laboratory that conform to the latest Underwriters Laboratories (U/L) Standards (also known as UL2034 Standards).

#### General Location Requirements:

Every single family dwelling and every multifamily dwelling unit shall be provided with a minimum of one approved and fully operational carbon monoxide alarm installed within ten (10) feet of each room lawfully used for sleeping purposes. If bedrooms are located on separate floors additional carbon monoxide alarms would be necessary within ten feet of these areas.

#### Owner Responsibilities in Multifamily Dwellings:

It shall be the owner's responsibility of a multifamily dwelling that is required to be equipped with carbon monoxide alarms to:

- (1) provide and install one approved and operational carbon monoxide alarm within ten feet of each room lawfully used for sleeping; and
- (2) replace any required carbon monoxide alarm that has been stolen, removed, found missing, or rendered inoperable during a prior occupancy of the dwelling unit and which has not been replaced by the occupant prior to the commencement of a new occupancy of a dwelling unit.

#### Battery Removal and Tampering Prohibited:

No person shall remove batteries from, or in any way render inoperable, a required carbon monoxide alarm.

